

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HS414		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner PEIRCE, ART					Phone # (414)249-1234		1. Well Location				Fire # (if avail.)						
Mailing Address PO BOX PELL LAKE							Town of PELL LAKE										
City PELL LAKE					State WI		Zip Code 53128										
County Walworth		Co. Permit # W15469		Notification #		Completed 11-14-1996		Subdivision Name PELL LAKE				Lot # Block #					
Well Constructor (Business Name) LOUIS G SIEVERT				Lic. # 475		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address 38827 90TH ST BURLINGTON WI 53105-8513				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 15 1 N 18 E											
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #		Common Well #		Specific Capacity 12													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)			
10		Surface		25		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				C		CLAY		Surface		9	
9		25		32						Y		SAND @ GRAVEL		9		29	
										G		GRAVEL		29		32	
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 15 ft. below ground surface				11. Well Is 20 in. above grade			
5		200 PSI PVC 1120 SRR21 FU 480 91 NCPWC JET STREAM				Surface		28		10. Pump Test Pumping level 16 ft. below surface Pumping at 12 GP M for 24 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
5		SS JOHNSON 25 SLOT				28		32									
7. Grout or Other Sealing Material Method PUMPED TIP																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
WYOBEEN DRILLING MUD @ CUTTINGS				Surface		252											
13. Constructor / Supervisory Driller LGS								Lic #		Date Signed							
Drill Rig Operator RJ								Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		39	Septic or Holding, or POWTS Tank		53

Comment:

Created On: 03-21-1997

Updated On: 03-21-1997

Review Status: