Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HT953

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SUNDLAND, DICK	Phone #: (715)634-8993
Mailing Address: RT 6 BOX 6527 B	
City: HAYWARD	State: WI — Zip Code: 54843
County: Sawyer	Co. Permit #: — Notification #: — Completed: 06-12-1995
Well Constructor (Business Name): ROBERT FROEMEL	Lic. #: 4354 — Facility ID # (Public Wells):
Address: RT 5 BOX 5000F HAYWARD WI 54843-8994	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity:

1. Well Location

Town of LENROOT

Fire # (if avail.):

Street Address or Road Name and Number: HWY 27 S

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SE	SW	Section	Township	Range
or Govt Lot #	001	33	41 N	9 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Driven Point

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole	Lower Open Bedrock
Rotary - Mud Circulation	
Rotary - Air	
Rotary - Air & Foam	
Drill-Through Casing Hammer	
Reverse Rotary	
Cable-tool Bit ____in. dia...	
Dual Rotary	
Temp. Outer Casing ____in. dia	

6. Casing, Liner, Screen — Removed? ____depth ft. (If NO explain on back side)

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	GALVANIZED	Surface	31.42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
2	STAINLESS STEEL 10	31.42	35

7. Grout or Other Sealing Material

Method

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	35

9. Static Water Level

17 ft. below ground surface

10. Pump Test

Pumping level 17 ft. below surface

Pumping at 10 GP M for 1.5 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NEW

13. Constructor / Supervisory Driller	Lic #	Date Signed
RD		06-12-1995
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65
Building Drain - Sanitary		15
Building Overhang		4
Downspout/Yard Hydrant		10
Sewer - Building Sanitary		15
Septic or Holding, or POWTS Tank		35

Comment:

Created On: 07-20-1995 Updated On: 07-20-1995 Review Status: