Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HV332

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HUEBNER, HOWARD		Phone #: (715)362-2158
Mailing Address: 4299 W LK GEORGE RD		
City: RHINELANDER	State: WI	Zip Code: 54501
County: Oneida	Co. Permit #:	Notification #: / Completed: 12-14-1994

Well Constructor (Business Name): TERRENCE BECKLEY	Lic. #: 353	Facility ID # (Public Wells):
Address: 3107 BUS HWY 51 L TOMAHAWK WI 54487-8838		Well Plan Approval #: Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of PELICAN

Fire # (if avail.): 4299

Street Address or Road Name and Number: W LAKE GEORGE RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.6134 °N -89.3428 °W	GCD013

NW or Govt Lot #	NW	Section	Township	Range
		14	36 N	9 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
POINT PLUGGED

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	57

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	40
C	CLAY	40	45
S	SAND	45	57

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18 97 LBS PER FOOT ASTM A 53 SAWHILL USA PE	Surface	54
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	NO M STAINLESS STEEL 10 X 3	54	57

7. Grout or Other Sealing Material
Method NONE

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 48 ft. below surface
Pumping at 10 GP M for 12 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
TB		01-05-1995
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TR		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		85
Building Drain - Sanitary		42

Type	Qualifier	Distance
Building Overhang		8
Sewer - Building Sanitary		42
Septic or Holding, or POWTS Tank		70

Comment:

Created On: 04-21-1995 Updated On: 06-30-2020 Review Status: