Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HV333

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: JEFSON, MARY	Phone #: (715)453-2040
Mailing Address: 7578 NOSE LK RD	
City: RHINELANDER	State: WI — Zip Code: 54501
County: Oneida	Co. Permit #: — Notification #: — Completed: 12-16-1994
Well Constructor (Business Name): TERRENCE BECKLEY	Lic. #: 353 — Facility ID # (Public Wells):
Address: 3107 BUS HWY 51 L TOMAHAWK WI 54487-8838	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.2

1. Well Location

Town of WOODBORO				Fire # (if avail.): 7578
Street Address or Road Name and Number: NOSE LAKE RD				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.5978 °N -89.5681 °W				Method Code: GCD013
NE	NE	Section: 24	Township: 36 N	Range: 7 E
or Govt Lot #				

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?: NEW HOME
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	56

Upper Enlarged Drillhole — Lower Open Bedrock
Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	56

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	PE 18 97 LBS PER FOOT ASTM A 53 SAWHILL USA	Surface	53
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	NOM STAINLESS STEEL 12	53	56

9. Static Water Level
34 ft. below ground surface

10. Pump Test
Pumping level 44 ft. below surface
Pumping at 12 GP M for 72 Hrs.
Pumping Method ?

11. Well Is
15 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
TB		01-05-1995
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60
Building Drain - Sanitary		40

Type	Qualifier	Distance
Building Overhang		10
Sewer - Building Sanitary		40
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-28-1995 Updated On: 06-30-2020 Review Status: