

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HV473		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A																							
Property Owner NEUMAN, BILL						Phone # (608)462-8704		1. Well Location				Fire # (if avail.)																					
Mailing Address CTY RD P						Town of PLYMOUTH						W1032																					
City ELROY						State WI		Zip Code 53929				Street Address or Road Name and Number CO P TRACY LN																					
County Juneau		Co. Permit #		Notification #		Completed 11-09-1999		Subdivision Name				Lot #		Block #																			
Well Constructor (Business Name) JIM PARKHURST JR				Lic. # 320		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code																			
Address 28700 OTTOMAN AV ELROY WI 53929-9801				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE NW Section Township Range or Govt Lot # 20 15 N 2 E		2. Well Type New Well				of previous unique well # constructed in																			
Hicap Permanent Well #				Common Well #		Specific Capacity 10				Reason for replaced or reconstructed well ?				Construction Type Drilled																			
3. Well serves 1 # of Private, potable						Hicap Well ? No						Hicap Property ? No		Hicap Potable ?																			
Heat Exchange ___ # of drillholes						4. Potential Contamination Sources - ON REVERSE SIDE						5. Drillhole Dimensions and Construction Method		8. Geology																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)													
10		Surface		56		Rotary - Mud Circulation				Rotary - Air				Rotary - Air & Foam				Drill-Through Casing Hammer				Reverse Rotary				R - C - RED CLAY		Surface		24			
6		56		225		Yes Cable-tool Bit 6in. dia...				No				Dual Rotary				Yes Temp. Outer Casing 10in. dia				Yes Removed? ___depth ft. (If NO explain on back side)				- S N - SOFT SANDROCK				24		80	
6		NEW STEEL 1897 PL SAWHILL A53		Surface		56				Dia. (in.) Screen type, material & slot size				From (ft.)				To (ft.)				E - H - GREEN SHALE		80		150							
6		NEW STEEL 1897 PL SAWHILL A53		Surface		56				Dia. (in.) Screen type, material & slot size				From (ft.)				To (ft.)				I H N - HARD WHITE SANDROCK		150		225							
6. Casing, Liner, Screen						9. Static Water Level						11. Well Is																					
Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.) To (ft.)						185 ft. below ground surface						12 in. above grade															
6 NEW STEEL 1897 PL SAWHILL A53						Surface						56						Developed ? Yes															
Dia. (in.) Screen type, material & slot size						From (ft.) To (ft.)						Pumping level 186 ft. below surface						Disinfected ? Yes															
Pumping Method ?						Pumping at 10 GP M for 8 Hrs.						Capped ? Yes																					
7. Grout or Other Sealing Material						12. Notified Owner of need to fill & seal ?						Filled & Sealed Well(s) as needed?						No															
Method PUMPED						Kind of Sealing Material						From (ft.) To (ft.) # Sacks Cement						NONE															
NEAT CEMENT						Surface						56						25 S															
13. Constructor / Supervisory Driller						Lic #						Date Signed																					
JP						11-09-1999						Drill Rig Operator						Lic or Reg #						Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		12
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 06-25-2002

Updated On: 07-05-2002

Review Status: