Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HW030

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PETKOFF, MICHAEL			Phone #
Mailing Address: 4204 ORANGE ST			
City: DELAVAN	State: WI	Zip Code: 53115	
County: Adams	Co. Permit #	Notification #	Completed: 10-12-1994

Well Constructor (Business Name): DOLATA EXCAVATING @ WELL	Lic. #: 4709	Facility ID # (Public Wells)	
Address: 2543 HWY 13 ADAMS WI 53910-9801		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of STRONYS PRAIRIE

Fire # (if avail.): 1854

Street Address or Road Name and Number: 1854 W

Subdivision Name: ROCHE A CRI	Lot #: 2	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NE SE or Govt Lot #	Section: 34	Township: 18 N	Range: 5 E

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NO LONGER PRODUCING

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	49
1.25	49	51

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S		BROWN SAND	Surface	25
	A	Y		WHITE COARSE SAND MIXED WITH GRAVEL	25	51

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	GALV RDBZ THREADEL @ COUPLED ASTM A 53 589 SAWHILL	Surface	49
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	CLAYTON MARK FISH PT	49	51

7. Grout or Other Sealing Material
Method

9. Static Water Level
30 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
KW		10-26-1994
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JD		10-26-1994

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		54

Type	Qualifier	Distance
Building Overhang		5
Septic or Holding, or POWTS Tank		49

Comment:

Created On: 01-31-1995 Updated On: 01-31-1995 Review Status: