Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HW032

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ANDERSON, ROBERT			Phone #: (608)564-7815
Mailing Address: 1176A CHICAGO LN			
City: FRIENDSHIP	State: WI	Zip Code: 53910	
County: Adams	Co. Permit #:	Notification #:	Completed: 10-11-1994
Well Constructor (Business Name): DOLATA EXCAVATING @ WELL	Lic. #: 4709	Facility ID # (Public Wells):	
Address: 2543 HWY 13 ADAMS WI 53910-9801		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

1. Well Location

Town of BIG FLATS

Fire # (if avail.):

Street Address or Road Name and Number: HWY C

Subdivision Name: TROUT VALLEY WEST	Lot #:	Block #:	
Latitude / Longitude in Decimal Degree (DD): °N °W			Method Code:
NW NW or Govt Lot #	Section: 22	Township: 19 N	Range: 6 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: NO LONGER PRODUCING NON C

Construction Type: Jetted

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	59
1.25	59	61

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S		BROWN SAND	Surface	25
G		C		GREY CLAY	21	56
	A	Y		WHITE COURSE SAND MIXED W GRAVEL	56	61

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	GALV EKBZ THREADED PLOUPLED ASTM 58 589 SAWHILL	Surface	59
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25		59	61

9. Static Water Level

23 ft. below ground surface

10. Pump Test

Pumping level 45 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
KW		10-26-1994
Drill Rig Operator	Lic or Reg #	Date Signed
JD		10-26-1994

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		54	Building Overhang		4
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 01-24-1995 Updated On: 01-24-1995 Review Status: