Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HW054

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: REILLY, TIMOTHY			Phone #
Mailing Address: 685 TIMBERLINE TR 20			
City: HARTFORD	State: WI	Zip Code: 53027	
County: Adams	Co. Permit #	Notification #	Completed: 11-15-1995

Well Constructor (Business Name): DOLATA EXCAVATING @ WELL	Lic #: 4709	Facility ID # (Public Wells)	
Address: 2543 HWY 13 ADAMS WI 53910-9801		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.6	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of STRONGS PRAIRIE

Fire # (if avail.)

Street Address or Road Name and Number: CZECH DR

Subdivision Name: CSM NO 525	Lot #: 4	Block #

Latitude / Longitude in Decimal Degree (DD) °N °W
Method Code

NW SE or Govt Lot #	Section: 34	Township: 18 N	Range: 5 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Jetted

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	42
1.25	42	45

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y		S		YELLOW SAND	Surface	8
R		C		RED GREY CLAY	8	25
	M	S		MED WHITE SAND	25	45

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	R@D ASTM A589 2 IN IPS 154 WALL 3 75 LB PER FTTHREADED @ COUPLED SAWHILL TUBULAR DR	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	7 SLOT JOHNSON STAINLESS	42	45

7. Grout or Other Sealing Material
Method

9. Static Water Level
14 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TD		11-28-1995
Drill Rig Operator	Lic or Reg #	Date Signed
BW		11-28-1995

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80

Type	Qualifier	Distance
Building Overhang		3
Septic or Holding, or POWTS Tank		35

Comment:

Created On: 11-11-1996 Updated On: 11-11-1996 Review Status: