Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HW055

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WOLF, RON	Phone #
Mailing Address: 1308 N JAMES CT	
City: WAUWATOSA	State: WI — Zip Code: 53213
County: Adams	Co. Permit #	Notification #	Completed: 11-15-1995
Well Constructor (Business Name): DOLATA EXCAVATING @ WELL	Lic. #: 4709	Facility ID # (Public Wells)
Address: 2543 HWY 13 ADAMS WI 53910-9801	Well Plan Approval #
	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.5

1. Well Location

Town of BIG FLATS	Fire # (if avail.): 1148
Street Address or Road Name and Number: 1148 BIG HORN DR	
Subdivision Name	Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): 44.1206 °N -89.8073 °W	Method Code: GCD013
SW NE or Govt Lot #	Section: 17	Township: 19 N	Range: 6 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Jetted

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	53
1.25	53	56

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	S	YELLOW SAND	Surface	10
I		S		FINE WHITE SAND	10	25
G		C		GREY CLAY	25	40
	M	S		MED WHITE SAND	40	56

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	R@D ASTM A589 2 IN IPS 154 WALL 3 75 IN PER FTTHREADED @ COUPLED SAWHILL TUBULAR DIV	Surface	53
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
1.25	7 SLOT JOHNSON SEAMLESS	53	56

7. Grout or Other Sealing Material

Method

9. Static Water Level

19 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 10 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TD		11-28-1995
Drill Rig Operator	Lic or Reg #	Date Signed
BW		11-28-1995

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		3
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 11-11-1996 Updated On: 05-04-2020 Review Status: