

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HW055		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A								
Property Owner WOLF, RON						Phone #												
Mailing Address 1308 N JAMES CT						1. Well Location						Fire # (if avail.)						
City WAUWATOSA						State WI		Zip Code 53213				Town of BIG FLATS		1148				
County Adams						Co. Permit #		Notification #				Completed 11-15-1995		Street Address or Road Name and Number				
Well Constructor (Business Name)						Lic. #		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)		Method Code				
DOLATA EXCAVATING @ WELL						4709		Well Plan Approval #				44.1206 °N -89.8073 °W		GCD013				
Address 2543 HWY 13 ADAMS WI 53910-9801						Approval Date (mm-dd-yyyy)		SW NE		Section 17		Township 19 N		Range 6 E				
Hicap Permanent Well #						Common Well #		Specific Capacity 0.5				2. Well Type New Well						
3. Well serves 1 # of HOME						Hicap Well ? No		Private, potable				of previous unique well # constructed in						
Heat Exchange ___ # of drillholes						Hicap Property ? No		Hicap Potable ?				Reason for replaced or reconstructed well ?						
Construction Type Jetted																		
4. Potential Contamination Sources - ON REVERSE SIDE																		
5. Drillhole Dimensions and Construction Method																		
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole					Lower Open Bedrock				
2			Surface			53			Rotary - Mud Circulation									
1.25			53			56			Rotary - Air									
									Rotary - Air & Foam									
									Drill-Through Casing Hammer									
									Reverse Rotary									
									Cable-tool Bit ___ in. dia...									
									Dual Rotary									
									Temp. Outer Casing ___ in. dia									
									Removed? ___ depth ft. (If NO explain on back side)									
6. Casing, Liner, Screen																		
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.)			To (ft.)						
2			R@D ASTM A589 2 IN IPS 154 WALL 3 75 IN PER FTTHREADED @ COUPLED SAWHILL TUBULAR DIV						Surface			53						
Dia. (in.)			Screen type, material & slot size						From (ft.)			To (ft.)						
1.25			7 SLOT JOHNSON SEAMLESS						53			56						
7. Grout or Other Sealing Material																		
Method																		
8. Geology																		
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.)			To (ft.)						
Y S			YELLOW SAND						Surface			10						
I S			FINE WHITE SAND						10			25						
G C			GREY CLAY						25			40						
M S			MED WHITE SAND						40			56						
9. Static Water Level																		
19 ft. below ground surface																		
10. Pump Test																		
Pumping level 40 ft. below surface																		
Pumping at 10 GP M for 2 Hrs.																		
Pumping Method ?																		
11. Well Is																		
12 in. above grade																		
Developed ? Yes																		
Disinfected ? Yes																		
Capped ? Yes																		
12. Notified Owner of need to fill & seal ?																		
Filled & Sealed Well(s) as needed?																		
13. Constructor / Supervisory Driller																		
TD						Lic #				Date Signed								
Drill Rig Operator						Lic or Reg #				Date Signed								
BW										11-28-1995								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		3
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 11-11-1996

Updated On: 05-04-2020

Review Status: