

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				HX884		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner LAHIFF, PAT						Phone #													
Mailing Address N2162 SHORE DR						Town of PESHTIGO						Fire # (if avail.) N2162							
City MARINETTE				State WI		Zip Code 54143													
County Marinette		Co. Permit #		Notification #		Completed 12-22-1994		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) GREGORY L JOHNSON				Lic. # 625		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.0368 °N -87.6257 °W				Method Code GCD013							
Address N3719 LOUCKS RD PESHTIGO WI 54157-9750				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW SE		Section Township		Range							
								or Govt Lot # 30		30 N		24 E							
Hicap Permanent Well #				Common Well #		Specific Capacity 0		2. Well Type New Well SR308 replaces this well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ?		4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
10		Surface		12						S		SAND		Surface		40			
6		12		165		C		CLAY		40		95							
						S		SAND		95		105							
						C S		SANDY CLAY		105		134							
						L		LIME ROCK		134		165							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10 ft. below ground surface				12 in. above grade					
6		A53 VSP CORP W1945 280W THREADED @ COUPLE				Surface		135		10. Pump Test Pumping level 140 ft. below surface Pumping at 5 GP M for 18 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
7. Grout or Other Sealing Material Method Kind of Sealing Material From (ft.) To (ft.) # Sacks Cement PUDDLED CLAY Surface 12												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
13. Constructor / Supervisory Driller GJ						Lic #		Date Signed 12-28-1994											
Drill Rig Operator						Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Shoreline/Pool		110
Building Drain - Sanitary		45	Sewer - Building Sanitary		45
Building Overhang		10	Septic or Holding, or POWTS Tank		40

Comment:

Created On: 04-21-1995

Updated On: 10-22-2019

Review Status: