Well Construction Report
WISCONSIN UNIQUE WELL NUMBER HX885

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HOOGSTRA, MERLIN			Phone #
Mailing Address: N5390 HILLDALE DR			
City: PORTERFIELD	State: WI	Zip Code: 54159	
County: Marinette	Co. Permit #	Notification #	Completed: 05-10-1995

Well Constructor (Business Name): GREGORY L JOHNSON	Lic. #: 625	Facility ID # (Public Wells)	
Address: N3719 LOUCKS RD PESHTIGO WI 54157-9750		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.2	

1. Well Location

Town of LAKE				Fire # (if avail.): W5692
Street Address or Road Name and Number: W5692 CO HWY G				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code
SE SE or Govt Lot #	Section: 33	Township: 32 N	Range: 21 E	

2. Well Type New Well

of previous unique well # HX885 constructed in 95

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	20
6	20	85

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	32
N	SANDSTONE	32	57
L	LIMESTONE	57	72
N	SAND STONE	72	85

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	A53 VSP CORP W1945 280W THREADED @ COUPLE	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 70 ft. below surface

Pumping at 10 GP M for 18 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PUDDLED CLAY	Surface	20	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GJ		05-10-1995
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		15

Comment:

Created On: 06-15-1995 Updated On: 06-15-1995 Review Status: