

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				IA779		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner KRAMER, ELMER						Phone # (715)421-2553		1. Well Location				Fire # (if avail.)			
Mailing Address 2831 HOBNAIL CT						Town of GRAND RAPIDS									
City WISCONSIN RAPIDS						State WI		Zip Code 54494				Street Address or Road Name and Number 3731 41ST CT			
County Wood		Co. Permit #		Notification #		Completed 09-23-1997		Subdivision Name CAPE VISTA ESTS				Lot # 6	Block #		
Well Constructor (Business Name) ELMER L KRAMER				Lic. # 5026	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.3606 °N -89.774 °W				Method Code GCD013				
Address 2831 HOBNAIL CT WI RAPIDS WI 54494-7356				Well Plan Approval #		SW	NE	Section 27	Township 22 N	Range 6 E					
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity		2. Well Type New Well									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ?							
						Hicap Property ? No									
4. Potential Contamination Sources - ON REVERSE SIDE						Hicap Potable ?		Construction Type Driven Point							
5. Drillhole Dimensions and Construction Method												8. Geology			
Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia				Lower Open Bedrock				Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)	To (ft.)		
								S	SAND			Surface	44		
6. Casing, Liner, Screen						Removed? ___ depth ft. (If NO explain on back side)		9. Static Water Level				11. Well Is			
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)	To (ft.)	27 ft. below ground surface				14 in. above grade				
2	SAWHILL				Surface	44	10. Pump Test				Developed ? Yes				
Dia. (in.)	Screen type, material & slot size				From (ft.)	To (ft.)	Pumping level ___ ft. below surface				Disinfected ? Yes				
2	JOHNSON				40	44	Pumping at 10 GP M for 4 Hrs.				Capped ? Yes				
							Pumping Method ?								
7. Grout or Other Sealing Material Method												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes			
13. Constructor / Supervisory Driller								Lic #		Date Signed					
ELK															
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60	Downspout/Yard Hydrant		10
Building Drain - Sanitary	>	35	Sewer - Building Sanitary	>	35
Building Overhang		3	Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 04-21-1998

Updated On: 05-05-2020

Review Status: