

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				IA781		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BULIN, TOM						Phone # (715)344-3596		1. Well Location				Fire # (if avail.)									
Mailing Address 2460 WILLOW DR AP B						Town of ROME						Street Address or Road Name and Number 1310 BIRDIE TRL NEKOOSA									
City PLOVER				State WI		Zip Code 54167															
County Adams		Co. Permit #		Notification #		Completed 02-19-1997		Subdivision Name BIRDIE ADD OF LAKE ARROWHEAD				Lot # 10		Block #							
Well Constructor (Business Name) ELMER L KRAMER				Lic. # 5026		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1928 °N -89.8211 °W				Method Code GCD013							
Address 2831 HOBNAIL CT WI RAPIDS WI 54494-7356						Well Plan Approval #				SE NE Section Township Range or Govt Lot # 19 20 N 6 E		2. Well Type New Well of previous unique well # constructed in									
						Approval Date (mm-dd-yyyy)				Reason for replaced or reconstructed well ? NEW HOME											
Hicap Permanent Well #		Common Well #		Specific Capacity				Construction Type Driven Point													
3. Well serves 1 # of Private, potable				Hicap Well ? Hicap Property ?																	
Heat Exchange ____ # of drillholes				Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Upper Enlarged Drillhole Lower Open Bedrock Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)														9. Static Water Level 25 ft. below ground surface				11. Well Is 15 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes			
6. Casing, Liner, Screen								10. Pump Test Pumping level ____ ft. below surface Pumping at 10 GP M for 6 Hrs. Pumping Method ?													
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 10%;">Dia. (in.)</th> <th style="width: 40%;">Material, Weight, Specification Manufacturer & Method of Assembly</th> <th style="width: 15%;">From (ft.)</th> <th style="width: 15%;">To (ft.)</th> </tr> <tr> <td>2</td> <td>SAWMILL</td> <td>Surface</td> <td>40</td> </tr> </table>								Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)	2	SAWMILL								
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)																		
2	SAWMILL	Surface	40																		
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 10%;">Dia. (in.)</th> <th style="width: 40%;">Screen type, material & slot size</th> <th style="width: 15%;">From (ft.)</th> <th style="width: 15%;">To (ft.)</th> </tr> <tr> <td>2</td> <td>JOHNSON</td> <td>40</td> <td>44</td> </tr> </table>								Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)	2	JOHNSON	40	44						
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)																		
2	JOHNSON	40	44																		
7. Grout or Other Sealing Material Method								13. Constructor / Supervisory Driller Lic # Date Signed ELKR 02-19-1997 Drill Rig Operator Lic or Reg # Date Signed													
(Empty space for grout/sealing material details)																					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	40	Wastewater Sump	>	30
Building Drain - Sanitary	>	30	Sewer - Building Sanitary	>	30
Building Overhang		5	Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 09-29-1997

Updated On: 05-04-2020

Review Status: