Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IC688

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FAULTERSACK, DWIGHT	Phone #: (715)886-4322
Mailing Address: 11031 SANDY SPRINGS	
City: NEKOOSA	State: WI / Zip Code: 54457
County: Wood	Co. Permit #: / Notification #: / Completed: 09-29-1998
Well Constructor (Business Name): ROTH PLUMBING @ WELL DRILLING	Lic. #: 5857 / Facility ID # (Public Wells):
Address: W2867 HWY 73 S, NEKOOSA WI 54457	Well Plan Approval #: / Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: / Specific Capacity: 5

1. Well Location

Town of SARATOGA

Fire # (if avail.):

Street Address or Road Name and Number: 11031 SANDY SPRINGS DR

Subdivision Name: SANDY SPRING / Lot #: / Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W / Method Code:

SE SE or Govt Lot # / Section: 15 / Township: 21 N / Range: 5 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

OLD WELL PLUGGING

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	34.6

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	10
		Y		SAND @ GRAVEL	10	26
	A	Y		CRS SAND @ GRAVEL	26	34.6

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	SAWHILL USA ASTMA53B HEAT #55051 6 98	Surface	31.6
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON SS 12 SLOT	31.6	34.6

9. Static Water Level

22.4 ft. below ground surface

10. Pump Test

Pumping level 24.4 ft. below surface

Pumping at 10 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

HOME OWNER WILL SEAL

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		09-30-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		58	Sewer - Building Sanitary		42
Building Drain - Sanitary		33	Fuel Oil Tank		27
Building Overhang		13	Septic or Holding, or POWTS Tank		54

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Casing Depth Variance	10/21/1998	< REQUIRED 10' OF CASING BELOW STATIC WATER LEVEL

Created On: 11-23-1998 Updated On: 11-23-1998 Review Status: