Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IC692

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: REED, WILLIAM	Phone #: (414)282-9224
Mailing Address: 5215 S 2ND PL	
City: MILWAUKEE	State: WI — Zip Code: 53221
County: Adams	Co. Permit #: — Notification #: — Completed: 11-01-1998
Well Constructor (Business Name): ROTH PLUMBING @ WELL DRILLING	Lic. #: 5857 — Facility ID # (Public Wells):
Address: W2867 HWY 73 S, NEKOOSA WI 54457	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 7.5

1. Well Location

Town of ROME

Fire # (if avail.):

Street Address or Road Name and Number: 1309 EAGLE TRL

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 44.1904 °N -89.8227 °W — Method Code: GCD013

NE SE or Govt Lot #: — Section: 19 — Township: 20 N — Range: 6 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	55

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	S			SAND	Surface	34
	C			CLAY	34	40
V	S	C		CLAY @ FINE SAND	40	48
A	Y			CRS SAND @ GRAVEL	48	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL USA A53B 6 625X280 PE WELDED	Surface	52
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	JOHNSON 12 SLOT	52	55

9. Static Water Level

32 ft. below ground surface

10. Pump Test

Pumping level 34 ft. below surface

Pumping at 15 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR		11-03-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		25	Building Overhang		6
			Wastewater Sump		64

Comment:

Created On: 01-19-1999 Updated On: 05-04-2020 Review Status: