

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				IC692		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner REED, WILLIAM						Phone # (414)282-9224		1. Well Location				Fire # (if avail.)									
Mailing Address 5215 S 2ND PL						Town of ROME						Street Address or Road Name and Number									
City MILWAUKEE						State WI		Zip Code 53221				1309 EAGLE TRL									
County Adams		Co. Permit #		Notification #		Completed 11-01-1998		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) ROTH PLUMBING @ WELL DRILLING				Lic. # 5857		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.1904 °N -89.8227 °W				Method Code GCD013							
Address W2867 HWY 73 S NEKOOSA WI 54457				Well Plan Approval #				NE SE		Section 19		Township 20 N		Range 6 E							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 7.5				2. Well Type New Well				of previous unique well #		constructed in					
Reason for replaced or reconstructed well ? NEW HOME																					
3. Well serves 1 # of						Hicap Well ? No				Construction Type Drilled											
Private, potable						Hicap Property ? No															
Heat Exchange ___ # of drillholes						Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		55										S		SAND		Surface		34	
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								C		CLAY		34		40	
														V S C		CLAY @ FINE SAND		40		48	
														A Y		CRS SAND @ GRAVEL		48		55	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		32 ft. below ground surface				12 in. above grade							
6		SAWHILL USA A53B 6 625X280 PE WELDED				Surface		52		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 34 ft. below surface				Disinfected ? Yes							
6		JOHNSON 12 SLOT				52		55		Pumping at 15 GP M for 4 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material Method														Pumping Method ?							
														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														RR						11-03-1998	
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		25	Building Overhang		6
			Wastewater Sump		64

Comment:

Created On: 01-19-1999

Updated On: 05-04-2020

Review Status: