

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				IE791		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner HENKE, ROGER						Phone # (715)536-8101		1. Well Location				Fire # (if avail.)									
Mailing Address NELSON RD						Town of BIRCH															
City IRMA						State WI		Zip Code 54442													
County Lincoln		Co. Permit #		Notification #		Completed 10-05-1995		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) JAMES A HORNUNG				Lic. # 695		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address W4014 ALPINE AVE MERRILL WI 54452-9064				Well Plan Approval #		Approval Date (mm-dd-yyyy)		NE NE Section Township Range or Govt Lot # 19 33 N 7 E													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5		2. Well Type New Well of previous unique well # constructed in													
Reason for replaced or reconstructed well ? NEW HOME																					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?				Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method												8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		115		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								S		SAND		Surface		35	
														S M		SAND SILT		35		100	
														C		CLAY		100		115	
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		45 ft. below ground surface				18 in. above grade							
6		6 625 ASTM A53 B WELDED SAWHILL 280 18 97				Surface		115		10. Pump Test Pumping level 70 ft. below surface Pumping at 12 GP M for 1 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material Method NONE												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed					
NONE				Surface		0				JHS						10-05-1995					
										Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		120	Foundation Drain to Clearwater		40
Building Overhang		40	Sewer - Building Sanitary		60
			Septic or Holding, or POWTS Tank		100

Comment:

Created On: 01-03-1996

Updated On: 01-03-1996

Review Status: