Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IG247

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OAK SPRINGS INC	Phone #: (414)695-9655
Mailing Address: 7019 LAKE RD	
City: DE FOREST	State: WI — Zip Code: 53532
County: Dane	Co. Permit #: W11103 — Notification #: — Completed: 06-07-1995
Well Constructor (Business Name): LARRY J SLAGER	Lic. #: 140 — Facility ID # (Public Wells):
Address: PO BOX 405 BRANDON WI 53919-0405	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1

1. Well Location

Town of WINDSOR

Fire # (if avail.):

Street Address or Road Name and Number: MEADOWWOOD RD

Subdivision Name	Lot #	Block #
OAK SPRINGS	90 91	

Latitude / Longitude in Decimal Degree (DD): 43.23987 °N -89.34629 °W — Method Code: GPS008

SE or Govt Lot #	SE	Section: 18	Township: 9 N	Range: 10 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: FUTURE NEW HOMES

Construction Type: Drilled

3. Well serves 2 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	102
6	102	134

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	8
Z	CLAY @ GRAVEL	8	25
Y	SAND @ GRAVEL	25	82
N	SANDROCK	82	134

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 18 97 LB PER FT 2600 PSI AP15L GRB P E USA SAWHILL	Surface	102
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD @ CUTTINGS	Surface	6	
CEMENT	6	102	15 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

N A

13. Constructor / Supervisory Driller	Lic #	Date Signed
TRO		06-07-1995
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Collector Sewer - San or Storm	>	70

Comment:

Created On: 10-05-1995 Updated On: 09-08-2022 Review Status: