Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IG563

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ERICSON, MARC			Phone #: (608)374-2202
Mailing Address: 800 TOWNLINE RD			
City: TOMAH	State: WI	Zip Code: 54660	
County: Juneau	Co. Permit #:	Notification #:	Completed: 07-27-1998

Well Constructor (Business Name): NELSONS PLBG @ ELEC INC	Lic. #: 42	Facility ID # (Public Wells):	
Address: RT 3 HWY 12 @ 16 TOMAH WI 54660-9803		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 2.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of GERMANTOWN

Fire # (if avail.): NA

Street Address or Road Name and Number: 28TH AVE

Subdivision Name: PLAT OF SURVEY DONE 9 4 93	Lot #: 4	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

NE NW or Govt Lot #:	Section: 3	Township: 17 N	Range: 4 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	32

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	32

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL WELD SAWHILL A53 18 97#	Surface	29
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
6	10 SLOT STAINLESS	29	32

7. Grout or Other Sealing Material

Method NA

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NA	Surface	0	

9. Static Water Level
13.5 ft. below ground surface

10. Pump Test
Pumping level 22 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
LN		07-29-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MN		07-29-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang	>	12

Comment:

Created On: 09-25-1998 Updated On: 09-25-1998 Review Status: