

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				IG563		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner ERICSON, MARC						Phone # (608)374-2202		1. Well Location				Fire # (if avail.)			
Mailing Address 800 TOWNLINE RD						Town of GERMANTOWN						NA			
City TOMAH						State WI		Zip Code 54660				Street Address or Road Name and Number 28TH AVE			
County Juneau		Co. Permit #		Notification #		Completed 07-27-1998		Subdivision Name PLAT OF SURVEY DONE 9 4 93				Lot # 4		Block #	
Well Constructor (Business Name) NELSONS PLBG @ ELEC INC				Lic. # 42		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code			
Address RT 3 HWY 12 @ 16 TOMAH WI 54660-9803				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 3 17 N 4 E		2. Well Type New Well				of previous unique well # constructed in			
Hicap Permanent Well #		Common Well #		Specific Capacity 2.4		Reason for replaced or reconstructed well ?				Construction Type Drilled					
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Heat Exchange ___ # of drillholes				Hicap Potable ?			
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock						
6		Surface		32											
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 6in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
S		SAND				Surface		32							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL WELD SAWHILL A53 18 97#				Surface		29							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		10 SLOT STAINLESS				29		32							
7. Grout or Other Sealing Material															
Method NA															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
NA		Surface		0											
9. Static Water Level															
13.5 ft. below ground surface															
10. Pump Test															
Pumping level 22 ft. below surface															
Pumping at 20 GP M for 2 Hrs.															
Pumping Method ?															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? NA															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
LN						07-29-1998									
Drill Rig Operator				Lic or Reg #		Date Signed									
MN						07-29-1998									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang	>	12

Comment:

Created On: 09-25-1998

Updated On: 09-25-1998

Review Status: