

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				IG567		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SCHUR MAINTENANCE @ CONSTRUCTI						Phone # (608)780-3050		1. Well Location				Fire # (if avail.)			
Mailing Address 804 DOUGLAS						Town of ANGELO						10786			
City SPARTA						State WI		Zip Code 54656				Street Address or Road Name and Number HWY 21			
County Monroe		Co. Permit #		Notification #		Completed 10-02-1998		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) NELSONS PLBG @ ELEC INC				Lic. # 42		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9693 °N -90.7773 °W				Method Code GCD013	
Address RT 3 HWY 12 @ 16 TOMAH WI 54660-9803				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 7 17 N 3 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? 2 INCH IN A PIT NON COMPL Construction Type Drilled							
Hicap Permanent Well #				Common Well #		Specific Capacity 1.8									
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock												
8 Surface 31			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 8in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 6in. dia <u>No</u> Removed? ___depth ft. (If NO explain on back side)												
6 31 55															
8. Geology															
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)						
S			SAND						Surface 13						
N			WHITE SANDSTONE						13 55						
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)									
6		STEEL SAWHILL A53 WELD 18 97#				Surface 37									
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)									
7. Grout or Other Sealing Material															
Method PRESSURE PUMPED															
Kind of Sealing Material			From (ft.) To (ft.) # Sacks Cement												
NEAT CEMENT			Surface 31 5 S												
9. Static Water Level															
12 ft. below ground surface															
10. Pump Test															
Pumping level 20 ft. below surface Pumping at 14 GP M for 24 Hrs. Pumping Method ?															
11. Well Is															
24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? No OWNER TO SEAL OLD 2 INCH WELL															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
LN															
Drill Rig Operator				Lic or Reg #				Date Signed							
MN								10-12-1998							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50	Foundation Drain to Sewer		35
Building Drain - Sanitary		35	Shoreline/Pool	>	100
Building Overhang		15	Nonconforming Pit or Alcove	>	30
Downspout/Yard Hydrant		15	Sewer - Building Sanitary		35
			Septic or Holding, or POWTS Tank	>	35

Comment:

Created On: 01-15-1999

Updated On: 04-29-2020

Review Status: