Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IG567

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHUR MAINTENANCE @ CONSTRUCTI	Phone #: (608)780-3050
Mailing Address: 804 DOUGLAS	
City: SPARTA	State: WI — Zip Code: 54656
County: Monroe	Co. Permit #: — Notification #: — Completed: 10-02-1998
Well Constructor (Business Name): NELSONS PLBG @ ELEC INC	Lic. #: 42 — Facility ID # (Public Wells):
Address: RT 3 HWY 12 @ 16 TOMAH WI 54660-9803	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.8

1. Well Location

Town of ANGELO	Fire # (if avail.): 10786
Street Address or Road Name and Number: HWY 21	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.9693 °N -90.7773 °W	Method Code: GCD013
NW NE or Govt Lot #:	Section: 7 — Township: 17 N — Range: 3 W

2. Well Type Replacement

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: 2 INCH IN A PIT NON COMPL

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	31
6	31	55

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 8in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 6in. dia
- No — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	13
I		N		WHITE SANDSTONE	13	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL SAWHILL A53 WELD 18 97#	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

12 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 14 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	31	5 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

OWNER TO SEAL OLD 2 INCH WELL

13. Constructor / Supervisory Driller	Lic #	Date Signed
LN		
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MN		10-12-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	50
Building Drain - Sanitary		35
Building Overhang		15
Downspout/Yard Hydrant		15

Type	Qualifier	Distance
Foundation Drain to Sewer		35
Shoreline/Pool	>	100
Nonconforming Pit or Alcove	>	30
Sewer - Building Sanitary		35
Septic or Holding, or POWTS Tank	>	35

Comment:

Created On: 01-15-1999 Updated On: 04-29-2020 Review Status: