Well Construction Report
WISCONSIN UNIQUE WELL NUMBER II756

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHROUD, TOM			Phone #: (608)635-7380
Mailing Address: N3111 HWY V			
City: POYNETTE	State: WI	Zip Code: 53955	
County: Columbia	Co. Permit #:	Notification #:	Completed: 12-20-1995

Well Constructor (Business Name): WICKHAMS WATER SERVICE INC	Lic. #: 4540	Facility ID # (Public Wells):	
Address: W10558 HWY J LODI WI 53555		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity:	

1. Well Location

Town of DE KORRA				Fire # (if avail.): N3111
Street Address or Road Name and Number: N3111 HWY V				
Subdivision Name: TOWN OF DE KORRA			Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): 43.39 °N -89.5236 °W				Method Code: GCD013
SE NE or Govt Lot #:	Section: 34	Township: 11 N	Range: 8 E	

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

OLD POINT NOT CODE

Construction Type: Driven Point

3. Well serves 1 # of 0

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	4
2	4	12
1.25	12	21

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	23
Y	SAND @ GRAVEL	23	27

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2.5	WHITEWATER STEEL ADT	Surface	5.5
1.25	1 1 4 GALVANIZED STEEL	5.5	23
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	JOHNSON STAINLESS 60 SLOT	23	27

7. Grout or Other Sealing Material

Method GRANULAR BENTONITE GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	12	1 S

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 15 ft. below surface

Pumping at 3 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

22 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

WILL BE DONE WEATHER PERMITTIN

13. Constructor / Supervisory Driller	Lic #	Date Signed
MW		12-29-1995
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Sewer - Building Sanitary		34
			Septic or Holding, or POWTS Tank		50

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Casing Depth Variance	01/22/1996	LESS THEN REQURD 25' OF CASING

Created On: 04-18-1996 Updated On: 04-02-2020 Review Status: