Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IK168

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: VAN CAMP, GARY	Phone #: (920)749-0169
Mailing Address: W5031 WEGE RD	
City: APPLETON	State: WI — Zip Code: 54915
County: Oconto	Co. Permit #: — Notification #: — Completed: 11-07-1997
Well Constructor (Business Name): EDWIN LEFEBER	Lic. #: 608 — Facility ID # (Public Wells):
Address: 14809 BEAR PAW TRL, MOUNTAIN WI 54149-9594	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity:

1. Well Location

Town of BREED	Fire # (if avail.): 10435
Street Address or Road Name and Number: 10435 PESHTIGO BROOK RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.0553 °N -88.3646 °W	Method Code: GCD013
NE NE or Govt Lot #:	Section: 25 — Township: 30 N — Range: 17 E

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: NEW HOME
Construction Type: Driven Point

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Upper Enlarged Drillhole / Lower Open Bedrock
- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia

6. Casing, Liner, Screen — Removed? ____depth ft. (If NO explain on back side)

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	SAWHILL ASTMA589 T@C R@D DRIVE PIPE	Surface	28
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
2	SS #60 SIMMONS	28	31

7. Grout or Other Sealing Material
Method

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	31

9. Static Water Level
13 ft. below ground surface

10. Pump Test
Pumping level 13 ft. below surface
Pumping at 7 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
EL		11-07-1997
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
LL		11-07-1997

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75

Type	Qualifier	Distance
Building Overhang		2
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 02-09-1998 Updated On: 11-15-2019 Review Status: