# Well Construction Report
## *WISCONSIN UNIQUE WELL NUMBER* IK169

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

| | | | |
|---|---|---|---|
| Property Owner: PIASESKI, KIM | | | Phone #: (715)276-7007 |
| Mailing Address: 17189 BOWMAN AVE | | | |
| City: TOWNSEND | State: WI | Zip Code: 54175 | |
| County: Oconto | Co. Permit #: | Notification #: | Completed: 11-25-1997 |

| | | | |
|---|---|---|---|
| Well Constructor (Business Name): EDWIN LEFEBER | Lic. #: 608 | Facility ID # (Public Wells): | |
| Address: 14809 BEAR PAW TRL<br>MOUNTAIN WI 54149-9594 | | Well Plan Approval #: | |
| | | Approval Date (mm-dd-yyyy): | |
| Hicap Permanent Well #: | Common Well #: | Specific Capacity: | |

**1. Well Location**

Town of RIVERVIEW

Fire # (if avail.):

Street Address or Road Name and Number: HOLTS SPUR RD

| | | |
|---|---|---|
| Subdivision Name: | Lot #: | Block #: |

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

| | | | |
|---|---|---|---|
| NE SW or Govt Lot #: | Section: 21 | Township: 32 N | Range: 16 E |

**2. Well Type** Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: OLD WELL NOT CODE

Construction Type: Driven Point

**3. Well serves** 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

**4. Potential Contamination Sources - ON REVERSE SIDE**

**5. Drillhole Dimensions and Construction Method**

| Upper Enlarged Drillhole | Lower Open Bedrock |
|---|---|
| Rotary - Mud Circulation ..... | |
| Rotary - Air ..... | |
| Rotary - Air & Foam ..... | |
| Drill-Through Casing Hammer | |
| Reverse Rotary | |
| Cable-tool Bit ____in. dia... | |
| Dual Rotary ..... | |
| Temp. Outer Casing ____in. dia | |

**6. Casing, Liner, Screen** Removed? ____depth ft. (If NO explain on back side)

| Dia. (in.) | Material, Weight, Specification Manufacturer & Method of Assembly | From (ft.) | To (ft.) |
|---|---|---|---|
| 2 | TEF R@D DRIVE PIPE | Surface | 26 |
| Dia. (in.) | Screen type, material & slot size | From (ft.) | To (ft.) |
| 2 | SS #60 SIMMONS | 26 | 29 |

**7. Grout or Other Sealing Material**

Method

**8. Geology**

| Geology Codes | | | | Type, Caving/Noncaving, Color, Hardness, etc... | From (ft.) | To (ft.) |
|---|---|---|---|---|---|---|
| | | S | | SAND | Surface | 29 |

**9. Static Water Level**

8 ft. below ground surface

**10. Pump Test**

Pumping level 8 ft. below surface

Pumping at 5 GP M for 5 Hrs.

Pumping Method ?

**11. Well Is**

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

**12.** Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

| **13.** Constructor / Supervisory Driller | Lic # | Date Signed |
|---|---|---|
| EL | | 11-29-1997 |
| **Drill Rig Operator** | **Lic or Reg #** | **Date Signed** |
| LL | | 11-29-1997 |

**4a. Potential Contamination Sources** Is the well located in floodplain ?

| Type | Qualifier | Distance | Type | Qualifier | Distance |
|---|---|---|---|---|---|
| POWTS dispersal component (soil absorption unit or mound) | | 70 | Building Overhang | | 3 |
| | | | Septic or Holding, or POWTS Tank | | 27 |

Comment:

Created On: 06-10-1998 Updated On: 06-10-1998 Review Status: