Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IL692

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NELSON, DIANA			Phone #: (414)984-3438
Mailing Address: N6854 STATE RD			
City: BLACK CREEK	State: WI	Zip Code: 54106	
County: Outagamie	Co. Permit #:	Notification #:	Completed: 11-29-1995

Well Constructor (Business Name): SCHMIDTS WATER SERVICE	Lic. #: 6	Facility ID # (Public Wells):	
Address: W5406 12 CORNER RD BLACK CREEK WI 54106-9803		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of MAINE

Fire # (if avail.):

Street Address or Road Name and Number: HWY 187

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

SW SW or Govt Lot #	Section: 27	Township: 24 N	Range: 16 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	220
6	220	240

Upper Enlarged Drillhole — Lower Open Bedrock

Yes
- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	35
		C		CLAY	35	73
		C	G	CLAY @ STONES	73	219
		N		SAND STONE	219	240

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 18 97 ASTM A53 MAVERICK TX PIPEDRIVE SHOE TOTAL	Surface	223
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD @ CUTTINGS	Surface	220	

9. Static Water Level
21 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
36 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAS		11-29-1995
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		71	Septic or Holding, or POWTS Tank		63

Comment:

Created On: 01-08-1996 Updated On: 01-08-1996 Review Status: