Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IL693

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: HART, BRIAN	Phone #: (414)833-2145
Mailing Address: 4625 SHADY RD	
City: BLACK CREEK	State: WI — Zip Code: 54106
County: Shawano	Co. Permit #: — Notification #: — Completed: 11-22-1995
Well Constructor (Business Name): SCHMIDTS WATER SERVICE	Lic. #: 6 — Facility ID # (Public Wells):
Address: W5406 12 CORNER RD, BLACK CREEK WI 54106-9803	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5
3. Well serves 1 # of	Hicap Well ?: No
Private,potable	Hicap Property ?: No
Heat Exchange____# of drillholes	Hicap Potable ?

1. Well Location
Town of LESSOR
Fire # (if avail.):
Street Address or Road Name and Number: SHADY RD
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:
SE SE or Govt Lot # — Section: 36 — Township: 25 N — Range: 17 E

2. Well Type New Well — XB862 replaces this well of previous unique well # — constructed in
Reason for replaced or reconstructed well ?: NEW HOME TRAILER
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.5	Surface	45
6	45	100

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	45
L	LIMESTONE	45	100

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 18 97 ASTM A53 MAVERICK TX PIPEDRIVE SHOE TOTAL	Surface	47
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
58 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 10 GP M for 8 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ?: Yes
Disinfected ?: Yes
Capped ?: Yes

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD @ CUTTINGS	Surface	45	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAS		11-22-1995
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-08-1996 Updated On: 02-08-2013 Review Status: