Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IL699

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HOELZEL, JERRY			Phone #: (414)725-9434
Mailing Address: 2593 W FAIRVIEW RD			
City: NEENAH	State: WI	Zip Code: 54956	
County: Outagamie	Co. Permit #:	Notification #:	Completed: 12-05-1995

1. Well Location

Town of GRAND CHUTE

Fire # (if avail.):

Street Address or Road Name and Number: HWY JJ

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
SCHMIDTS WATER SERVICE	6	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

Well Plan Approval #:

NW	NE	Section	Township	Range
or Govt Lot #		5	21 N	17 E

Address: W5406 12 CORNER RD
BLACK CREEK WI 54106-9803

Approval Date (mm-dd-yyyy):

2. Well Type New Well — WO636 replaces this well of previous unique well # — constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.4

Reason for replaced or reconstructed well ?
NEW HOME

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	41
6	41	140

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	CLAY @ STONES	Surface	28
		L		LIMESTONE	28	105
		N		SAND STONE	105	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 18 97 ASTM A53 MAVERICK TX PIPEDRIVE SHOE TOTAL	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
55 ft. below ground surface

10. Pump Test
Pumping level 80 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method: PUMPED CONCRETE TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	41	9 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAS		12-06-1995
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		37

Comment:

Created On: 01-08-1996 Updated On: 08-17-2010 Review Status: