

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				IL699		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner HOELZEL, JERRY						Phone # (414)725-9434		1. Well Location				Fire # (if avail.)							
Mailing Address 2593 W FAIRVIEW RD						Town of GRAND CHUTE													
City NEENAH						State WI		Zip Code 54956				Street Address or Road Name and Number HWY JJ							
County Outagamie		Co. Permit #		Notification #		Completed 12-05-1995		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) SCHMIDTS WATER SERVICE				Lic. # 6		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address W5406 12 CORNER RD BLACK CREEK WI 54106-9803				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 5 21 N 17 E		2. Well Type New Well WO636 replaces this well of previous unique well # constructed in											
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		Reason for replaced or reconstructed well ? NEW HOME													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
9		Surface		41		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				C G		CLAY @ STONES		Surface		28			
6		41		L						LIMESTONE		28		105					
				N						SAND STONE		105		140					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		55 ft. below ground surface				12 in. above grade					
6		NEW BLACK STEEL 18 97 ASTM A53 MAVERICK TX PIPEDRIVE SHOE TOTAL				Surface		42		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 80 ft. below surface				Disinfected ? Yes					
										Pumping at 10 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method PUMPED CONCRETE TREMIE PIPE												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT				Surface		41		9 S		TAS						12-06-1995			
										Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		37

Comment:

Created On: 01-08-1996

Updated On: 08-17-2010

Review Status: