Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IL700

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BENNETT, BRUCE			Phone #: (414)841-9540
Mailing Address: N2104 GREENVILLE DR			
City: HORTONVILLE	State: WI	Zip Code: 54944	
County: Outagamie	Co. Permit #:	Notification #:	Completed: 11-30-1995

1. Well Location

Town of GREENVILLE

Fire # (if avail.):

Street Address or Road Name and Number: HWY 45

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): SCHMIDTS WATER SERVICE	Lic. #: 6	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W
		Well Plan Approval #:	Method Code:
Address: W5406 12 CORNER RD, BLACK CREEK WI 54106-9803		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	

SW SE or Govt Lot #:	Section: 4	Township: 21 N	Range: 16 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.5	Surface	40
6	40	60

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	G	CLAY @ STONES	Surface	13
		C		CLAY	13	27
		L		LIMESTONE	27	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 18 97 ASTM A53 MAVERICK TX PIPEDRIVE SHOE TOTAL	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

9 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 10 GP M for 8 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method PUMPED CONCRETE TREMIE PIPE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	40	8 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAS		11-30-1995
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		12

Comment:

Created On: 01-08-1996 Updated On: 01-08-1996 Review Status: