Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IW073

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BOECK, ALAN	Phone #: (608)325-5187
Mailing Address: W5395 MELVIN RD	
City: MONROE	State: WI — Zip Code: 53566
County: Green	Co. Permit #: — Notification #: — Completed: 06-06-1995

1. Well Location

Town of CLARNO	Fire # (if avail.): W5395
Street Address or Road Name and Number: MELVIN RD	
Subdivision Name: — Lot #: — Block #: —	
Latitude / Longitude in Decimal Degree (DD): 42.562 °N -89.6262 °W	Method Code: GCD013
NE NE or Govt Lot #	Section: 14 — Township: 1 N — Range: 7 E

Well Constructor (Business Name): NIFFENEGGER, ED JR	Lic. #: 135 — Facility ID # (Public Wells): — Well Plan Approval #: — Approval Date (mm-dd-yyyy): —
Address: 902 2ND ST MONROE WI 53566	
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 1.3	

2. Well Type New Well
of previous unique well #: — constructed in: —
Reason for replaced or reconstructed well ?: WATER FOR NEW HOME
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	82
6	82	200

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air ..... — No
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	F	I	FILL & TOPSOIL	Surface	2
T	-	C	-	BROWN CLAY	2	8
-	B	L	-	BROKEN GALENA LIMESTONE	8	9
Y	-	L	-	BUFF GALENA LIMESTONE	9	70
U	-	L	-	BLUE PLATTEVILLE LIMESTONE	70	170
-	-	N	-	ST PETER SANDSTONE	170	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD WT ST .280 WALL 18.97 PER FT PL END-WELDED JTS SAWHILL A53B ASTM	Surface	82
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
123 ft. below ground surface

10. Pump Test
Pumping level 135 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	82	20 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
RN		07-21-1995
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75

Type	Qualifier	Distance
Building Overhang		12
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 10-11-2005 Updated On: 01-21-2020 Review Status: