

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				IW101		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner SCHARTNER, TOM						Phone # (608)966-1730		1. Well Location				Fire # (if avail.)	
Mailing Address W7881 SMOCK VALLEY R						Town of JORDAN						W7881	
City BROWNTOWN						State WI		Zip Code 53522				Street Address or Road Name and Number SMOCK VALLEY RD	
County Green		Co. Permit #		Notification #		Completed 05-04-1995		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) ED NIFFENEGGER JR				Lic. # 135		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.6099 °N -89.7482 °W				Method Code GCD013	
Address 902 2ND ST MONROE WI 53566-1103				Well Plan Approval #		NW NE Section Township Range or Govt Lot # 35 2 N 6 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? WATER FOR NEW HOME					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #		Common Well #		Specific Capacity 2.1		Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8.75		Surface		62									
6		62		160									
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T		I		TOPSOIL		Surface		1					
		C		BROWN CLAY		1		4					
		N		SANDSTONE		4		160					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		STD WT ST 280 WALL 18 97 LB PER FT PL END WELDEDJTS SAWHILL A53B ASTM				Surface		62					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material Method PRESSURE													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
NEAT CEMENT		Surface		62		15 S							
9. Static Water Level 88 ft. below ground surface													
10. Pump Test Pumping level 95 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ?													
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
RN								06-06-1995					
Drill Rig Operator						Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75	Building Overhang		25
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 10-19-1995

Updated On: 01-21-2020

Review Status: