Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IW101

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SCHARTNER, TOM	Phone #: (608)966-1730
Mailing Address: W7881 SMOCK VALLEY R	
City: BROWNTOWN	State: WI — Zip Code: 53522
County: Green	Co. Permit #:
Notification #	Completed: 05-04-1995
Well Constructor (Business Name): ED NIFFENEGGER JR	Lic. #: 135
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 902 2ND ST MONROE WI 53566-1103	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 2.1	

1. Well Location

Town of JORDAN	Fire # (if avail.): W7881
Street Address or Road Name and Number: SMOCK VALLEY RD	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 42.6099 °N -89.7482 °W	Method Code: GCD013

NW	NE	Section	Township	Range
or Govt Lot #		35	2 N	6 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?
WATER FOR NEW HOME

Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	62
6	62	160

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	1
T		C		BROWN CLAY	1	4
		N		SANDSTONE	4	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD WT ST 280 WALL 18 97 LB PER FT PL END WELDEDJTS SAWHILL A53B ASTM	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
88 ft. below ground surface

10. Pump Test
Pumping level 95 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	62	15 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RN		06-06-1995
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75

Type	Qualifier	Distance
Building Overhang		25
Septic or Holding, or POWTS Tank		35

Comment:

Created On: 10-19-1995 Updated On: 01-21-2020 Review Status: