Well Construction Report
WISCONSIN UNIQUE WELL NUMBER IW102

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BAUER, TED	Phone #: (708)349-1533
Mailing Address: 10900 CRYSTAL SPRING	
City: ORLAND PARK	State: IL — Zip Code: 60462
County: Lafayette	Co. Permit #: — Notification #: — Completed: 05-15-1995
Well Constructor (Business Name): ED NIFFENEGGER JR	Lic. #: 135 — Facility ID # (Public Wells):
Address: 902 2ND ST, MONROE WI 53566-1103	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.1

1. Well Location

Town of GRATIOT

Fire # (if avail.):

Street Address or Road Name and Number: WICK RD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SW SE or Govt Lot #: — Section: 3 — Township: 1 N — Range: 4 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: WATER FOR STORAGE BUILDIN

Construction Type: Drilled

3. Well serves # of STORAGE BUILDING FUTURE HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	62
6.062	0.16	0

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD WT ST 280 WALL 1897 LB PER FT PL END WELDED JTSAWHILL A53BN ASTM	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PRESSURE TREMIE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	62	15 S

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	1
T		C		BROWN CLAY	1	5
Y		L		BUFF LIMESTONE	5	35
U		L		BLUE LIMESTONE	35	65
T		L		BUFF LIMESTONE	65	110
		N		SANDSTONE	110	160

9. Static Water Level

62 ft. below ground surface

10. Pump Test

Pumping level 80 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
RN		06-06-1995
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	140	Building Overhang		80
			Septic or Holding, or POWTS Tank	>	120

Comment:

Created On: 09-07-1995 Updated On: 09-07-1995 Review Status: