Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KB288

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OGLESBEE, WES			Phone #
Mailing Address: 3623 BENJAMIN ST NE			
City: MINNEAPOLIS	State: MN	Zip Code: 55418	
County: Adams	Co. Permit #	Notification #	Completed: 10-28-1996

Well Constructor (Business Name): RAY E FOSTER	Lic. #: 164	Facility ID # (Public Wells)	
Address: 2540 HWY 13 ADAMS WI 53910		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity	

1. Well Location

Town of QUINCY

Fire # (if avail.)

Street Address or Road Name and Number: WI @ LINEHAN

Subdivision Name: DELLWOOD	Lot #: 1 5	Block #: 44

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SW NE or Govt Lot #	Section: 18	Township: 17 N	Range: 5 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW MOBILE HOME SITE

Construction Type: Jetted

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	6
2	6	46

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	N	S		BROWN SAND FINE	Surface	35
	A	S		LT BROWN COARSE SAND	35	46

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	SAWHILL TYPE ASTM A589 375	Surface	42
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	SS CAMPBELL SCREEN	42	46

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 14 ft. below surface

Pumping at 8 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD @ CUTTINGS	Surface	6	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
RF		11-20-1996
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DF		11-20-1996

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		54
Building Overhang		4

Type	Qualifier	Distance
Sewer - Building Sanitary		18
Septic or Holding, or POWTS Tank		36

Comment:

Created On: 02-17-1997 Updated On: 02-17-1997 Review Status: