

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KB288		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner OGLESBEE, WES						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address 3623 BENJAMIN ST NE						Town of QUINCY																	
City MINNEAPOLIS						State MN		Zip Code 55418				WI @ LINEHAN											
County Adams		Co. Permit #		Notification #		Completed 10-28-1996		Subdivision Name DELLWOOD				Lot # 1 5 Block # 44											
Well Constructor (Business Name) RAY E FOSTER				Lic. # 164		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code											
Address 2540 HWY 13 ADAMS WI 53910				Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W													
Hicap Permanent Well #		Common Well #		Specific Capacity		SW NE Section Township Range or Govt Lot # 18 17 N 5 E		2. Well Type New Well				of previous unique well # constructed in											
Reason for replaced or reconstructed well ?						NEW MOBILE HOME SITE																	
3. Well serves 1 # of Private, potable						Hicap Well ? No		Construction Type Jetted															
Heat Exchange ___ # of drillholes						Hicap Property ? No																	
Hicap Potable ?																							
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method																							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
6		Surface		6		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				N S		BROWN SAND FINE		Surface		35							
2		6		46						A S		LT BROWN COARSE SAND		35		46							
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		14 ft. below ground surface				12 in. above grade									
2		SAWHILL TYPE ASTM A589 375				Surface		42		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 14 ft. below surface				Disinfected ? Yes									
1.25		SS CAMPBELL SCREEN				42		46		Pumping at 8 GP M for 1 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?											
Method																							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				No									
MUD @ CUTTINGS				Surface		6				NONE													
13. Constructor / Supervisory Driller								Lic #		Date Signed													
RF										11-20-1996													
Drill Rig Operator								Lic or Reg #		Date Signed													
DF										11-20-1996													

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		54	Sewer - Building Sanitary		18
Building Overhang		4	Septic or Holding, or POWTS Tank		36

Comment:

Created On: 02-17-1997

Updated On: 02-17-1997

Review Status: