

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KC489		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner MEADOW BROOK HOMES						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address W339 N9550 TOWNLINE								Town of MERTON									
City OCONOMOWOC						State WI		Zip Code 53066									
County Waukesha		Co. Permit #		Notification #		Completed 10-15-1998		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) GIBOUR WELL @ PUMP				Lic. # 4212		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code					
Address 7482 CIRCLE DR LANNON WI 53046				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 6 8 N 18 E		2. Well Type New Well				of previous unique well # constructed in					
Hicap Permanent Well #		Common Well #		Specific Capacity 3.6		Reason for replaced or reconstructed well ? HOME											
3. Well serves 1 # of Private, potable				Hicap Well ? No		Hicap Property ? No		Construction Type Drilled									
Heat Exchange ___ # of drillholes				Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		58						Y		SAND @ GRAVEL		Surface		21	
						Rotary - Mud Circulation				Z		CLAY @ GRAVEL		21		29	
						Rotary - Air				Y		SAND @ GRAVEL		29		58	
						Rotary - Air & Foam											
						Drill-Through Casing Hammer											
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		13 ft. below ground surface		36 in. above grade					
6		ASTM A53B BE SAWHILL WELDED				Surface		58		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface		Disinfected ? Yes					
										Pumping at 25 GP M for 2 Hrs.		Capped ? Yes					
										Pumping Method ?							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?							
GRANULAR BENTON				Surface		0											
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												BG				10-16-1998	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Clearwater Sump		35

Comment:

Created On: 11-24-1998

Updated On: 11-24-1998

Review Status: