

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KC490		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner KEHL, DERRICK						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address W4410 E HILLCREST RD						Town of HUSTIFORD																	
City JUNEAU						State WI		Zip Code 53039				Street Address or Road Name and Number W4410 E HILLCREST RD											
County Dodge		Co. Permit #		Notification #		Completed 10-17-1998		Subdivision Name				Lot # Block #											
Well Constructor (Business Name) GIBOUR WELL @ PUMP				Lic. # 4212		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.3102 °N -88.6148 °W				Method Code GCD013									
Address 7482 CIRCLE DR LANNON WI 53046				Well Plan Approval #		NW NW Section Township Range or Govt Lot # 28 10 N 16 E				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? HOME													
						Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #		Common Well #		Specific Capacity 1																			
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled																	
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		43		Yes Rotary - Mud Circulation						Z S		SANDY CLAY @ GRAVEL		Surface		26					
6		43		110		Rotary - Air						Z		CLAY @ GRAVEL		26		37					
						Rotary - Air & Foam						L		LIMESTONE		37		110					
						Drill-Through Casing Hammer																	
						Reverse Rotary																	
						Cable-tool Bit ___ in. dia...																	
						Dual Rotary																	
						Temp. Outer Casing ___ in. dia																	
						Removed? ___ depth ft. (If NO explain on back side)																	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		30 ft. below ground surface				18 in. above grade									
6		ASTM A 53 B BE SAWHILL WELDED				Surface		43		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 40 ft. below surface				Disinfected ? Yes									
										Pumping at 10 GP M for 1.5 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method BRADEN														Filled & Sealed Well(s) as needed?									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						13. Constructor / Supervisory Driller				Lic #		Date Signed			
NEAT CEMENT GRO				Surface		43		15 S						BG						10-18-1998			
														Drill Rig Operator				Lic or Reg #		Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		131	Clearwater Sump		48
Building Overhang		13	Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 01-07-1999

Updated On: 10-01-2019

Review Status: