Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KC491

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BECKER, DEAN			Phone #
Mailing Address: W298 N521 KINGSWAY D			
City: WAUKESHA	State: WI	Zip Code: 53188	
County: Waukesha	Co. Permit #	Notification #	Completed: 10-21-1998

Well Constructor (Business Name): GIBOUR WELL @ PUMP	Lic. #: 4212	Facility ID # (Public Wells)	
Address: 7482 CIRCLE DR LANNON WI 53046		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 10	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of DELAFIELD

Fire # (if avail.)

Street Address or Road Name and Number: W298 N521 KINGSWAY DR

Subdivision Name: STONEHENGE	Lot #: 5	Block #

Latitude / Longitude in Decimal Degree (DD): 43.0373 °N -88.3416 °W				Method Code: GCD013
NW SW or Govt Lot #	Section: 26	Township: 7 N	Range: 18 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	53

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	CLAY @ GRAVEL	Surface	39
Y	SAND @ GRAVEL	39	53

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B BE SAWHILL WELDED	Surface	51
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	COOK SS #2K	51	53

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTON	Surface	0	

9. Static Water Level
24 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
BG		10-21-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	200
Building Overhang		30
Clearwater Sump	>	50
Wastewater Sump		30
Septic or Holding, or POWTS Tank		30

Comment:

Created On: 11-24-1998 Updated On: 07-12-2019 Review Status: