Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KC720

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KERKVLIET, STEVEN	Phone #: (715)832-3054
Mailing Address: 2010 ESMOND RD STE 2	
City: EAU CLAIRE	State: WI — Zip Code: 54701
County: Eau Claire	Co. Permit #: W15422 — Notification #: — Completed: 11-03-1998
Well Constructor (Business Name): PELKE PLBG HTG @ WELL DRLG INC	Lic. #: 535 — Facility ID # (Public Wells):
Address: N6298 STATE HWY 25 DURAND WI 54736-9105	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 5

1. Well Location

Town of SEYMOUR	Fire # (if avail.): 1118
Street Address or Road Name and Number: 1118 BAUER AVE	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.8261 °N -91.4243 °W	Method Code: GCD013
NW NW or Govt Lot #:	Section: 13 — Township: 27 N — Range: 9 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: NEW CONSTRUCTION
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	84

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOP SOIL	Surface	1
		S	M	SILTY SAND	1	70
	A	S		COARSE LIGHT BROWN SAND	70	84

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ST T@C ASTM A53 GR B 19 45LBS SAWHILL USA	Surface	80
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	4X48 JOHNSON 10 SLOT SS	80	84

7. Grout or Other Sealing Material

Method GRAVIY FED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE @ DRILL SLU	Surface	0	

9. Static Water Level
67 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 15 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
DOES NOT APPLY

13. Constructor / Supervisory Driller	Lic #	Date Signed
REP		11-11-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JP		11-11-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60
Building Overhang		6

Type	Qualifier	Distance
Sewer - Building Sanitary	>	18
Septic or Holding, or POWTS Tank	>	54

Comment:

Created On: 11-24-1998 Updated On: 08-01-2019 Review Status: