Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KC721

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BLOOM, BRUCE			Phone #: (715)926-4498
Mailing Address: 855 JEFFERSON			
City: MONDOVI	State: WI	Zip Code: 54755	
County: Buffalo	Co. Permit #:	Notification #:	Completed: 11-03-1998

1. Well Location

Town of NAPLES

Fire # (if avail.):

Street Address or Road Name and Number: DEER RUN RD

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): PELKE PLBG HTG @ WELL DRLG INC	Lic. #: 535	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): °N °W	Method Code:
Address: N6298 STATE HWY 25 DURAND WI 54736-9105		Well Plan Approval #:	NW NW or Govt Lot #	Section: 5
		Approval Date (mm-dd-yyyy):		Township: 24 N
				Range: 10 W

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: NEW CONSTRUCTION

Construction Type: Drilled

Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.7

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	60
6	60	115

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Yes — Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	I			TOPSOIL	Surface	1
S	N			SOFT SANDSTONE	1	54
H	N	N		HARD LIGHT GRAY SANDSTONE @ LAYER OF	54	115

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ST T@C ASTM A53 GR B 19 45 LBS SAWHILL USA	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

52 ft. below ground surface

10. Pump Test

Pumping level 75 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	60	18 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

DOES NOT APPLY

13. Constructor / Supervisory Driller	Lic #	Date Signed
REP		11-11-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JP		11-11-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75	Foundation Drain to Clearwater	>	20
Building Overhang	>	15	Septic or Holding, or POWTS Tank	>	75

Comment:

Created On: 11-24-1998 Updated On: 11-24-1998 Review Status: