Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KC722

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: TROLLER, PEGGY	Phone #: (715)643-2064
Mailing Address: 1106 CHARLOTTE ST #5	
City: BOYCEVILLE	State: WI — Zip Code: 54725
County: Dunn	Co. Permit #: — Notification #: — Completed: 11-05-1998
Well Constructor (Business Name): PELKE PLBG HTG @ WELL DRLG INC	Lic. #: 535 — Facility ID # (Public Wells):
Address: N6298 STATE HWY 25, DURAND WI 54736-9105	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location
Town of STANTON
Fire # (if avail.):
Street Address or Road Name and Number: 130TH ST GOLF VALLEY RD
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:
NW NW or Govt Lot # — Section: 9 — Township: 29 N — Range: 14 W

2. Well Type New Well
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?
NEW CONSTRUCTION
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	40
6	40	80

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Yes — Temp. Outer Casing 10in. dia
- Yes — Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	1
		S		SAND	1	12
		N		SANDSTONE	12	31
		L		LIMESTONE	31	44
	H	N		HARD LIGHT GREEN SANDSTONE	44	60
	H	N		HARD BROWN SANDSTONE	60	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ST PE ASTM A53 GR B 19 45 LBS SAWHILL USA	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
34 ft. below ground surface

10. Pump Test
Pumping level 60 ft. below surface
Pumping at 13 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method: TREMIE PIPE PRESSURE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND CEMENT	Surface	40	12 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
DOES NOT APPLY

13. Constructor / Supervisory Driller	Lic #	Date Signed
REP		11-11-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JP		11-11-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	75
Building Overhang	>	12
Foundation Drain to Clearwater	>	13
Sewer - Building Sanitary	>	48
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 11-24-1998 Updated On: 11-24-1998 Review Status: