

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KC867		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner PERDZOK, CLYDE						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 9223 8 MILE RD						Town of CITY POINT						Street Address or Road Name and Number KNUTES RD			
City FRANKSVILLE				State WI		Zip Code 53126									
County Jackson		Co. Permit #		Notification #		Completed 10-24-1998		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) JON A RUSH				Lic. # 5837		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code	
Address RT 2 BOX 152 BLACK RIVER FALLS WI 54615-9801				Well Plan Approval #				°N		°W		NE NE Section Township Range or Govt Lot # 21 22 N 1 E			
				Approval Date (mm-dd-yyyy)											
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3				2. Well Type New Well					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?				Reason for replaced or reconstructed well ? NO WATER							
								Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		50		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 6in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
Q		S		SAND CAVING GRAY				Surface		34					
H		N		SANDROCK HARD GRAY				34		50					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STEEL #18 97 FT ASTM A53B SAWHILL USA WELDED				Surface		34							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
6		STEEL #18 97 FT ASTM A53B SAWHILL USA WELDED				Surface		34							
7. Grout or Other Sealing Material Method															
9. Static Water Level 12 ft. below ground surface															
10. Pump Test Pumping level 18 ft. below surface Pumping at 8 GP M for 4 Hrs. Pumping Method ?															
11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
JAR								11-24-1998							
Drill Rig Operator								Lic or Reg #		Date Signed					
11-24-1998								11-24-1998							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Sewer - Building Sanitary		40
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 01-19-1999

Updated On: 01-19-1999

Review Status: