Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KC867

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PERDZOK, CLYDE			Phone #
Mailing Address: 9223 8 MILE RD			
City: FRANKSVILLE	State: WI	Zip Code: 53126	
County: Jackson	Co. Permit #	Notification #	Completed: 10-24-1998

Well Constructor (Business Name): JON A RUSH	Lic. #: 5837	Facility ID # (Public Wells)	
Address: RT 2 BOX 152 BLACK RIVER FALLS WI 54615-9801		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of CITY POINT

Fire # (if avail.)

Street Address or Road Name and Number: KNUTES RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

NE or Govt Lot #	NE	Section: 21	Township: 22 N	Range: 1 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NO WATER

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	50

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Q	S		SAND CAVING GRAY	Surface	34
H	N		SANDROCK HARD GRAY	34	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL #18 97 FT ASTM A53B SAWHILL USA WELDED	Surface	34
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 18 ft. below surface
Pumping at 8 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAR		11-24-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Sewer - Building Sanitary		40
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 01-19-1999 Updated On: 01-19-1999 Review Status: