Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KC901

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FARMWELL, RUMPEL, DAVE	Phone #: (608)323-7179
Mailing Address: N31683 HICKORY HLS	
City: ARCADIA	State: WI — Zip Code: 54612
County: Trempealeau	Co. Permit #:
Notification #	Completed: 10-13-1998
Well Constructor (Business Name): PELKE GLEN PLBG HTG @ WELL DRLG	Lic. #: 131
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 835 RIVERSIDE AVE, MONDOVI WI 54755-1443	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.7	

1. Well Location

Town of ARCADIA

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SE	SE	Section	Township	Range
or Govt Lot #		18	21 N	9 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

WANTED MORE WATER FOR FAR

Construction Type: Drilled

3. Well serves 1 # of FARM

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
6	6	52

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	V	C		BLACK NONCAVING CLAY	Surface	5
	Q	S	M	GREY SILTY CAVING SAND	5	10
T		S	M	BROWN SILTY SAND	10	45
	A	S		COARSE BROWN SAND	45	52

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK T @ C PIPE ASTM A53 GR B LTV STEEL 19 45LBS A F SEIDEMAN	Surface	48
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	10 SLOT STAINLESS STEEL JOHNSON	48	52

7. Grout or Other Sealing Material

Method HAND FED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	6	

9. Static Water Level

5 ft. below ground surface

10. Pump Test

Pumping level 35 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GNP		10-19-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KO		10-19-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		300

Type	Qualifier	Distance
Building Overhang		5
Septic or Holding, or POWTS Tank		30

Comment:

Created On: 11-17-1998 Updated On: 11-17-1998 Review Status: