Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KC902

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RASSBACH, JAMES			Phone #: (715)532-2156
Mailing Address: 1835 WHITE OAK			
City: EAU CLAIRE	State: WI	Zip Code: 54703	
County: Rusk	Co. Permit #:	Notification #:	Completed: 10-19-1998

Well Constructor (Business Name): PELKE GLEN PLBG HTG @ WELL DRLG	Lic. #: 131	Facility ID # (Public Wells):	
Address: 835 RIVERSIDE AVE MONDOVI WI 54755-1443		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of BIG BEND
Street Address or Road Name and Number

Fire # (if avail.)

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

SE	NE	Section	Township	Range
or Govt Lot #		33	33 N	8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HSE CONSTRUCTION NO W

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	6
6	6	75

Upper Enlarged Drillhole
Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		S	M	BROWN SILTY SAND	Surface	15
G		S	U	GREY SILTY MUCKY SAND	15	60
		G		BROWN @ GRAY GRAVEL	60	75

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK T C PIPE ASTM A 53 GR B LTV STEEL 19 45LBS A F SEIDEMAN NNK	Surface	72
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL 10 SLOT JOHNSON	72	75

7. Grout or Other Sealing Material
Method HAND FED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY	Surface	6	

9. Static Water Level
5 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 25 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
GNP		10-28-1998
Drill Rig Operator	Lic or Reg #	Date Signed
KO		10-28-1998

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		10	Shoreline/Pool		100
			Septic or Holding, or POWTS Tank		75

Comment:

Created On: 01-15-1999 Updated On: 01-15-1999 Review Status: