

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KK315		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner JANIKOWSKI, JAMES					Phone # (715)536-9070		1. Well Location				Fire # (if avail.)			
Mailing Address N768 CENTER RD							Town of PINE RIVER				N768			
City MERRILL					State WI		Zip Code 54452		Street Address or Road Name and Number N768 CENTER RD					
County Lincoln		Co. Permit #		Notification #		Completed 09-27-1995		Subdivision Name LSM 649			Lot # 6		Block #	
Well Constructor (Business Name) JAMES A HORNING				Lic. # 695		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.1444 °N -89.647 °W			Method Code GCD013			
Address W4014 ALPINE AVE MERRILL WI 54452-9064						Well Plan Approval #		SW NW Section Township Range or Govt Lot # 29 31 N 7 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME				
						Approval Date (mm-dd-yyyy)								
Hicap Permanent Well #			Common Well #			Specific Capacity 3.8		Construction Type Drilled						
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		55										
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)					
Y			SAND GRAVEL			Surface			55					
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is 14 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes				
6		6 6250 SAWHILL ASTM A 53 B WELDED 18 97 280				Surface		52						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
5.5		020 SS JOHNSON				52		55						
7. Grout or Other Sealing Material														
Method NONE														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
NONE				Surface		0								
9. Static Water Level														
37 ft. below ground surface														
10. Pump Test														
Pumping level 41 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ?														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed? NONE														
13. Constructor / Supervisory Driller								Lic #		Date Signed				
JHS										09-27-1995				
Drill Rig Operator								Lic or Reg #		Date Signed				

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100	Foundation Drain to Clearwater		10
Building Overhang		11	Sewer - Building Sanitary		30
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-03-1996

Updated On: 06-15-2020

Review Status: