

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KK891		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SCHOLZ, DUANE						Phone # (715)386-3961		1. Well Location				Fire # (if avail.)					
Mailing Address 963 LABARGE RD						Town of HUDSON						Street Address or Road Name and Number 963 MCCUTCHEON RD @ LABARGE RD					
City HUDSON				State WI		Zip Code 54016											
County St. Croix		Co. Permit #		Notification #		Completed 08-09-1995		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) DAVID L MCCULLOUGH				Lic. # 72		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address 20335 FOREST BLVD N FOREST LAKE MN 55025-9764				Well Plan Approval #				SW NE		Section 14		Township 29 N		Range 19 W			
				Approval Date (mm-dd-yyyy)				or Govt Lot #		Township 29 N		Range 19 W					
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3				2. Well Type Replacement									
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? WELL WAS PUMPING FINE SAN									
						Hicap Property ? No											
4. Potential Contamination Sources - ON REVERSE SIDE						Hicap Potable ?		Construction Type Drilled									
						Hicap Potable ?											
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
8.75 Surface 255			Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						I TOP SOIL		Surface 2						
2 255 259									Y SAND GRAVEL		2 105						
									Z CLAY GRAVEL		105 170						
									C CLAY		170 245						
									S SAND		245 256						
			G GRAVEL		256 259		11. Well Is 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes										
6. Casing, Liner, Screen						9. Static Water Level											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		105 ft. below ground surface									
4		ASTMA53 IPSCO CAMANCHE 237 TC 11 LB				Surface 255		10. Pump Test Pumping level 145 ft. below surface Pumping at 10 GP M for 1 Hrs. Pumping Method ?									
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)											
2		STAINLESS STEEL SCREEN				253 259		12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? Yes WELL WILL BE SEALD AROUND NOV									
7. Grout or Other Sealing Material						13. Constructor / Supervisory Driller											
Method TREMIE						Lic #		Date Signed									
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement		DM		08-10-1995									
BENTONITE GROUT		Surface 20		2 S		Drill Rig Operator		Lic or Reg #		Date Signed							
DRIL MUD		20 255				DB				08-10-1995							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		50	Building Overhang		14
			Septic or Holding, or POWTS Tank		25

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Casing Depth Variance	07/12/1995	< REQUIRED AMOUNT OF CASING IN A SPECIAL AREA

Created On: 10-31-1995

Updated On: 10-31-1995

Review Status: