

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KK894		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner KLEM, KEN						Phone # (715)327-4681		1. Well Location				Fire # (if avail.)	
Mailing Address 10837 WHISPERING WIN						Town of TRADE LAKE							
City FREDERIC						State WI		Zip Code 54837					
County Burnett		Co. Permit #		Notification #		Completed 08-16-1995		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) DAVID L MCCULLOUGH				Lic. # 72		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address 20335 FOREST BLVD N FOREST LAKE MN 55025-9764				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 1 37 N 18 W		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.4		Reason for replaced or reconstructed well ?							
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled							
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ?									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock							
8.75		Surface		63		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
2		63		69									
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
I		TOP SOIL				Surface		2					
S		SAND				2		20					
Z		CLAY GRAVEL				20		50					
S		SAND				50		69					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
4		ASTMA53 IPSCO CAMANCHE 237 T C 11 LB				Surface		63					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
2		STAINLESS STEEL SCREEN				62		69					
7. Grout or Other Sealing Material													
Method TREMIE													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement							
BENTNITE GROUT		Surface		20		2 S							
DRILL MUD		20		63									
9. Static Water Level													
6 ft. below ground surface													
10. Pump Test													
Pumping level 30 ft. below surface													
Pumping at 10 GP M for 1 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
DM								08-16-1995					
Drill Rig Operator						Lic or Reg #		Date Signed					
DB								08-16-1995					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		12	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 11-02-1995

Updated On: 11-02-1995

Review Status: